

PROCEDURE FOR SWIMMING POOL CLEAN UP FECAL VOMIT DISCHARGE

Close Pool – all bathers must get out of the water

**Remove as much solid matter as possible with the skimming net & dispose in toilet –
DO NOT USE THE VACUUM!!**

Raise disinfectant level to 5 – 10 mg/l chlorine or equivalent

**Allow one complete filtration cycle (one turnover) of pool water to occur (8 hours or
less if turnover rate is known)**

Allow disinfectant level to adjust to 0.8 – 3.0 mg/l of chlorine

Backwash pool filter

Re open pool for use

Enter information in the Log Book

Notes:

- 1. It is recommended that children that are not toilet trained wear tight fitting plastic pants.**
- 2. Do NOT allow children with diarrhea in the pool. NO ONE should enter a pool or any other bathing area if they have diarrhea.**